



PO BOX 491, 163 SCHUYLER AVENUE
KEARNY, NEW JERSEY 07032
PHONE: 201-246-1115 FAX: 201-246-1831
www.nmsnj.com

This is to certify that meter number **52271562** was tested on site by National Metering Services, Inc. A New York State Public Service Commission Certified Meter Testing Facility located at 163 Schuyler Ave, Kearny, N.J., on **October 28, 2021**. Test results are as follows.

Water Company: **Tuxedo Park NY**

Size: **3/4x3/4"** Mfg: **Neptune** Test read: **093788030**

	<u>Result</u>	<u>Flow Rate</u> <u>G.P.M.</u>	<u>GAL</u>
High Flow.....	229.97 %	25	100
Intermediate Flow.....	99.9 %	3	10
Low Flow.....	97.4 %	1/2	10

Note: Test equipment is State of New Jersey & State of Connecticut Bureau of Weights and Measures certified and certified by the State of New York Public Service Commission.

STATUS OF METER AS RECEIVED

ACCURATE ___ HIGH **X** LOW ___ STOPPED ___ REPAIR ___ SCRAP ___
FAILED **X** PASSED ___