VILLAGE OF TUXEDO PARK

80 LORILLARD ROAD TUXEDO PARK, NEW YORK 10987

DPW Report February 21, 2024 to March 19, 2024

DPW

- 1. Cut and removed dangerous and fallen trees at the Racetrack
- 2. Removed large logs covering the Elephant Pit at the Racetrack and installed a precast concrete manhole
- 3. Fabricated and installed a cedar handrail at the north end of the Racetrack
- 4. Removed various fallen trees as a result of heavy winds
- 5. Cleaned drains and catch basins
- 6. Installed a new roadside mirror at the S turns on East Lake Road
- 7. Straightened various street signs
- 8. Cleaned roads, triangles, Village Office, Sewer Plant, and the Wee Wah Beach of debris after winds
- 9. Worked on deteriorated window at the Police State
- 10. Repaired roof on the screen room at the Sewer Plant after winds blew shingles off
- 11. Picked up broken blacktop berms from plowing

Water and Sewer

- 1. Repaired a leaking chlorine feed line at the Sewer Plant
- 2. Worked with leak detection company to pinpoint a leak on the Iazzetti property
- 3. Repaired leak on a 2" water main on the Iazzettti property and installed a new 2" shutoff valve
- 4. Began first quarter water meter readings
- 5. Continued weekend Water and Sewer operations
- 6. Obtained various meter readings per Denise Spalthoff
- 7. Obtained weekly meter readings on Village accounts
- 8. Did various utility mark-outs for Dig Safe NY
- 9. Repaired a sewer manhole on the Iazzetti property
- 10. Responded to 29 Serpentine Road for a broken water pipe in the home; turned off water line at the meter
- 11. Checked heat in all buildings and pump houses