



Environmental Service Inc.

November 16, 2022

John Ledwith
Building Inspector &
Consultant to the Village Board of Trustees
Village of Tuxedo Park
P.O. Box 31
Tuxedo Park, NY 10987

RE: Village of Tuxedo Park WWTP Weekly Flow and Operations Status Report

The daily flow average at the facility from Tuesday 11/7/22 through Sunday 11/13/22 was (.046 MGD). 1.5" precipitation recorded for the week.

- On Tues. 11/7/22, all daily operations were normal.
- On Wed. 11/8/22, all daily operations were normal.
- On Thurs. 11/9/22, all daily operations were normal.
- On Fri. 11/10/22, all daily operations were normal.
- On Sat. 11/11/22, all daily operations were normal.
- On Sun. 11/12/22, all daily operations were normal.
- On Sun. 11/13/22, all daily operations were normal.

Outstanding Issues/Concerns:

- No

If you have any questions or concerns about this report, please feel free to contact me.

Sincerely,

**Ray Robles
Operator (Tuxedo Park)
VRI Environmental Services, Inc.**

Village of Tuxedo Park WTP Flow Data 11/7/22 - 11/13/22

Plant	Date	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Total Flow
		11/7/2022	11/8/2022	11/9/2022	11/10/2022	11/11/2022	11/12/2022	11/13/2022	
Tuxedo WTP	Distribution	268,700	178,600	300,400	258,000	231,000	294,100	213,600	1,744,400
	Raw	299,200	184,200	334,000	273,200	242,200	296,100	222,700	1,851,600
	Backwash	30500	5600	33600	15200	11200	2000	9100	94.21%
11/7/2022	Normal operations. Coyne delivered 1-pallet of light soda ash = 54 bags								
11/8/2022	Normal operations. Slack delivered 90 gals of bulk chlorine.								
11/9/2022	Normal operations. Switch Filter Units and all chart recorders.								
11/10/2022	Normal operations.								
11/11/2022	Normal operations.								
11/12/2022	Normal operations. Changed the solution for the chlorine reagents analyzer.								
11/13/2022	Normal operations.								