

METER MALFUNCTION

2/1/2023

BOOK 1				PRIOR			MALFUNCTION
ACCT #	CUSTOMER	SERVICE ADDRESS	METER #	READING	READINGS	REASON	REPORT DATE
353	Verlaque	14 Tower Hill Loop	47824881	1,105,450	0	Same as Previous	12/16/2022
439	Cheung	90 Lorillard Road	47203027	9,562	0	Pad Stopped Working	12/20/2022
623	Booth	262 Tuxedo Road	47207738	1,190,250	0	Meter Head Stopped Working	9/20/2022

BOOK 2				PRIOR			MALFUNCTION
ACCT #	CUSTOMER	SERVICE ADDRESS	METER #	READING	READINGS	REASON	REPORT DATE
445	Simet	40 East Lake Stable	41848595	1,418,500	0	Same as Previous	12/20/2022

BOOK 3				PRIOR			MALFUNCTION
ACCT #	CUSTOMER	SERVICE ADDRESS	METER #	READING	READINGS	REASON	REPORT DATE
529	McQuilling	25 West Lake Stable	41704616	1,770,400	1,760,800	Negative Reading	12/30/2022

BOOK 4				PRIOR			MALFUNCTION
ACCT #	CUSTOMER	SERVICE ADDRESS	METER #	READING	READINGS	REASON	REPORT DATE
121	Farrell	37 Augusta Place	41704713	824,050	0	Pad Stopped Working	1/4/2023

BOOK 5				PRIOR			MALFUNCTION
ACCT #	CUSTOMER	SERVICE ADDRESS	METER #	READING	READINGS	REASON	REPORT DATE
61	Leandre	28 Hillside Avenue	41848547	2,351,300	0	Pad Stopped Working	1/5/2023
196	Bruno	36 Schoolhouse Road	36526887	42,750	0	Pad Removed During Constr.	1/5/2023