

Filtration Component

Instructions: Complete pages 1 and 2 of this form and submit to your local health department within 10 days of the close of the reporting month.

Complete page 3 if your system utilizes conventional or direct filtration and can answer "YES" to any of the four questions on page 3.

Public Water System Name		Reporting Month/Year					Type of Filtration		
Tuxedo Park Village		August-22					<input checked="" type="checkbox"/> Conventional	<input type="checkbox"/> Slow Sand	
Public Water System ID Number		Town, Village, or City	County						
NY3503557		Tuxedo	Orange		<input type="checkbox"/> Direct <input type="checkbox"/> Diatomaceous Earth				
Date	Entry Point Chlorine Residual (mg/L)						Distribution System Turbidity Results		
	0	400	800	1200	1600	2000	Sample Location	NTU	
1	1.30	1.50	1.50	1.40	1.20	1.20	Boat House	0.220	
2	0.90	1.50	1.30	1.10	1.10	1.10	Sewer Plant	0.240	
3	1.30	1.30	1.50	1.50	1.30	1.30	Library (Coliform S	0.180	
4	1.50	1.40	2.60	2.60	2.30	2.30	Voss	0.270	
5	2.30	2.30	2.25	1.75	1.50	1.50	ST Mary Church	0.290	
6	o/l	1.50	1.55	1.50	1.60	1.60			
7	1.60	1.55	1.50	1.50	1.40	1.40			
8	1.50	1.50	1.50	1.50	1.50	1.50	Sewer Plant	0.400	
9	1.40	1.39	1.50	1.40	1.50	1.50	Boat House	0.190	
10	1.50	1.30	1.50	1.50	1.40	1.40	Beach Bathroom	0.160	
11	1.40	1.50	1.20	1.30	1.20	1.20	Voss	0.250	
12	1.20	1.20	1.30	1.50	1.40	1.40	Tuxedo Library	0.160	
13	1.40	1.55	1.61	o/l	1.50	1.50			
14	1.50	1.50	1.50	1.40	1.40	1.40			
15	1.40	1.30	1.40	1.40	1.80	1.80	Sewer Plant	1.920	
16	1.90	1.90	1.50	1.50	1.40	1.40	Boat House	0.170	
17	1.40	1.60	1.70	1.60	1.60	1.60	s Deli (Coliform S	0.190	
18	1.80	1.60	1.40	1.60	1.80	1.80	Beach Bathroom	0.360	
19	1.70	1.50	1.50	1.51	1.52	1.52	Voss	0.260	
20	1.50	o/l	1.37	1.40	1.42	1.42			
21	1.50	1.40	1.60	1.80	1.80	1.80			
22	1.70	1.80	1.70	1.60	1.60	1.60	Sewer Plant	0.380	
23	1.30	1.30	1.70	1.80	1.90	1.90	Beach Bathroom	0.330	
24	1.70	1.80	1.70	1.60	1.60	1.60	Boat House	0.320	
25	1.50	1.40	1.50	1.47	1.49	1.49	Voss	0.240	
26	o/l	o/l	1.50	1.49	1.50	1.50	Tuxedo Library	0.210	
27	o/l	1.50	1.50	1.40	1.50	1.50			
28	1.30	1.40	1.60	1.60	1.50	1.50			
29	1.20	1.30	1.50	1.60	1.40	1.40	Sewer Plant	0.290	
30	1.40	1.40	1.40	o/l	1.00	1.00	Beach Bathroom	0.410	
31	1.40	1.40	1.20	1.30	1.50	1.50	Village Clerk	0.260	
							AVG	0.335	

Location of entry point _____ Water treatment facility _____
 Population served _____ 1,100 _____
 Entry point disinfection monitoring: Continuous Grab If Grab, how many samples per day? _____
 Monitoring results: Free Chlorine Total Chlorine
 Did the entry point residual fall below 0.2 mg/L for more than 4 hours?..... Yes No
 Did the monthly average of the distribution system turbidity results exceed 5 NTU?..... N/A Yes No

Reported by (print name) _____ Ray Robles _____ Title _____ Chief _____
 NYSDOH Operator Certification Number _____ NY0039172 _____ Operator Grade Level _____ IIA, IIB, C, D _____
 Signature _____ Date _____ 09/06/22 _____